

October Maintenance Report

WWTP:

- Pumping tanks & spreading with A-1 Pumping @ Ideker's once crop are out.
- Issues with the influent flow meter-new transducer did not fix the issue. Hoskins and Mid-west Flow Cal are working on solutions. A new monitor would cost ruffly \$7,000.00.

Lift Stations:

Streets:

- Repaired culvert on Hamilton St., new culvert was installed.
- Raised manhole on 9th & Benton.

Manor:

- North end water mitigation at the manor has been completed.

Training:

- PASSED Testing for bio-solids in Mankato, now hold a Type 40-Biosolid License!

Old Business:

- Storm water issues above Tim Serres looked at by TJ's when they were in town, they will submit a plan with estimate.
- F. Dvorak/R. Doering water mitigation-next spring.
- Exhaust fans @ manor this winter's project. Venting/re-sheeting next spring.
- FD well city maintenance will install new electrical panel due to corrosion & valve handle stop needs repair to help with turning on and shutting off.
- Looking for a second quote from MN Pump to replace gate and check valves as well as deteriorated discharge pipe under building. TJ's provided quote #1.
- Hoping to start repairing block on building soon.
- TJ's to install rail @ Harbor Lights ASAP.
- Hoskins to provide quote for new panels along with communication system.